

CLASSIFICATION OF FIRE RESISTANCE ACCORDING TO EN 13501-2: 2016 A NON-LOADBEARING METAL SANDWICH PANEL PARTITION OF TYPE “SAB WB 100.1000 EW30” MANUFACTURED BY SAB-PROFIEL BV

| | |
|--------------------|---|
| Classification no. | 2021-Efectis-R000384 |
| Sponsor | SAB-profiel BV P.O. Box 97 3400 AB IJSSELSTEIN THE NETHERLANDS |
| Product name | SAB WB 100.1000 EW30 |
| Prepared by | Efectis Nederland BV |
| Notified body no. | 1234 |
| Author(s) | A.J. Waber M.Sc. G.M. Klijn B.Sc. |
| Project number | ENL-20-001246 |
| Date of issue | March 2021 |
| Number of pages | 16 |

TABLE OF CONTENTS

| | | |
|-----|--|----|
| 1. | Introduction | 3 |
| 1.1 | Normative references | 3 |
| 1.2 | Revision information | 3 |
| 2. | Details of classified product | 3 |
| 2.1 | General | 3 |
| 2.2 | Description | 3 |
| 2.3 | Method of assembly | 8 |
| 3. | Test reports and test results in support of the classification | 8 |
| 3.1 | Test reports | 8 |
| 3.2 | Results | 9 |
| 4. | Classification and field of application | 9 |
| 4.1 | Reference of classification | 9 |
| 4.2 | Classification | 9 |
| 4.3 | Field of application | 9 |
| 4.4 | General | 9 |
| 4.5 | Extension of width | 10 |
| 4.6 | Extension of height | 10 |
| 4.7 | Supporting constructions | 10 |
| 5. | Limitations | 11 |
| 6. | Drawings | 12 |

1. INTRODUCTION

This classification report defines the resistance to fire classification assigned to “SAB WB 100.1000 EW30” in accordance with the procedures given in EN 13501-2:2016.

1.1 NORMATIVE REFERENCES

Table 1.1: Normative references

| European standard | Part |
|-------------------|---|
| EN 1363-1:2020 | Fire resistance tests – Part 1: General requirements |
| EN 1363-2:1999 | Fire resistance tests – Part 2: Alternative and additional procedures |
| EN 1364-1:2015 | Fire resistance tests for non-loadbearing elements - Part 1: Walls |
| EN 13501-2:2016 | Fire classification of construction products and building elements – Part 2: Classification using data from fire resistance tests, excluding ventilation services |

1.2 REVISION INFORMATION

This is the first issue of the classification report.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The element, “SAB WB 100.1000 EW30” is defined as a non-loadbearing metal sandwich panel construction.

2.2 DESCRIPTION

The element, “SAB WB 100.1000 EW30” is fully described below in support of classification listed in 3.1.

2.2.1 Test Frame

The test frame was constructed of steel beams comprising a fire-resistant concrete lining (density: $1450 \text{ kg/m}^3 \pm 200 \text{ kg/m}^3$), with an aperture of 4 x 3 m (w x h) with an insertion width of 250 mm.

2.2.2 Supporting Construction

An aerated concrete pier with a thickness of 250 mm was built into the test frame to achieve the necessary aperture dimensions.


Table 2.1: Specifications supporting construction

| Specifications standard low density rigid supporting construction | |
|--|--|
| Overall dimensions | 1000 x 3000 x 250 mm (w x h x t) |
| Aperture | 3000 x 3000 mm (w x h) |
| Material | Aerated concrete blocks: 600 x 250 x 150 mm |
| Manufacturer | Ytong |
| Density | 575 kg/m ³ ± 50 kg/m ³ |
| Thickness | 250 mm |

2.2.3 Restraint / Free edge

The specimen was erected so that the left vertical edge (seen from the unexposed side) was unrestrained as described in EN 1363-1. The gap was filled with mineral wool of type "Prorox SL 970" with a density of 115 kg/m³ to provide a seal without restricting freedom of movement. The gap was approx. 40 mm wide.


2.2.4 Partition

| Specifications partition | |
|--|----------------|
|  | |
| Manufacturer | SAB-profiel bv |

| | |
|--------------|---|
| Type | Non-loadbearing partition consisting of sandwich panels |
| Material | Steel and PIR foam |
| Product name | WB100.1000 |
| Dimensions | 3000 x 3000 x 100 mm (w x h x t) |
| Function | Fire resistant partition |
| Fixing | Connected with L-shaped profiles to the supporting construction |

2.2.5 Sandwich panel

Specifications sandwich panel




| | |
|--------------|---|
| Manufacturer | SAB-profiel bv |
| Type | Sandwich panel |
| Product name | WB100.1000 |
| Material | Outer layer exposed side: steel, 0.5 mm Core: PIR foam type "SAB VIII" with a density of 39 kg/m ³ Outer layer unexposed side: steel, 0.6 mm |
| Dimensions | 1000 x 3000 x 100 mm (w x h x t) |
| Function | Fire resistant partition |
| Fixing | Panels to the supporting construction: with L-shaped profiles. The panel was fixed with screws Ø5.5 x 25 mm to the L-shaped profile, at a c.t.c of approx. 333 mm. The L-shaped profile was fixed to the supporting construction with Ø8 x 60 mm screws and 8 mm plugs at a c.t.c of approx. 333 mm |

| | |
|--|--|
| | Panels to each other: on the exposed side with screws Ø4.8 x 90 mm at a c.t.c distance of approx. 333 mm |
|--|--|

2.2.6 Profiles

| Specifications profiles | |
|-------------------------|---|
| Manufacturer | SAB-profiel bv |
| Type | U-shaped profile L-shaped profile |
| Material | Galvanized steel |
| Dimensions | U-shaped profile: 100 x 50 x 0.6 mm (w x h x t) L-shaped profile: 100 x 50 x 1.5 mm (w x h x t) |
| Location | U-shaped profile: at the free edge capping the fitted sandwich panel L-shaped profile: around perimeter (except the free edge) on exposed and unexposed side |
| Function | U-shaped profile: sealing of the open edge of the fitted sandwich panel at the free edge L-shaped profile: connecting the sandwich panels to the supporting construction |
| Fixing | With screws Ø5.5 x 25 mm at a c.t.c distance of approx. 333 mm |

2.2.7 Sealant

| Specifications sealant | |
|--|---------|
|  <p style="text-align: center;">Fireside</p> | |
| Manufacturer | Celdex |
| Type | Sealant |

| | |
|--------------|---|
| Product name | Panelseal UF50A |
| Material | PUR |
| Dimensions | 6 x 59 mm |
| Location | At the vertical edges were the sandwich panels join |
| Function | Wind- and water tightness |
| Fixing | Self-adhesive |

2.2.8 Mineral wool

| Specifications mineral wool | |
|-----------------------------|---|
| Manufacturer | Rockwool |
| Type | Mineral wool |
| Product name | Prorox SL 970 |
| Density | 115 kg/m ³ |
| Material | Mineral wool |
| Location | Between sandwich panel and supporting construction at fixed edges Filling of the free edge |
| Function | Fire resistant sealing of gaps |
| Fixing | Stuffed into cavity |

2.2.9 Sealants

| Specifications sealant | |
|------------------------|---|
| Manufacturer | PFC Corofil |
| Type | Intumescent sealant |
| Product name | Firestop (acoustic intumescent sealant) |
| Material | Acrylic based sealant containing graphite |
| Location | Around perimeter of partition (except free edge) between L-shaped profile and panels Around perimeter of partition (except free edge) between L-shaped profile and supporting construction |
| Function | Sealing of gaps during fire |

2.2.10 Screws

| Specifications screws | |
|------------------------------|---|
| Type | Self-drilling screws |
| Product name | Saphir self-drilling screw: EJOT JT2 Self-drilling Firesafe screw |
| Material | Steel |
| Dimensions | Ø5.5 x 25 mm Ø8.0 x 60 mm Ø4.8 x 90 mm |
| Location | <p>Ø5.5 x 25 mm: around perimeter of the partition, on exposed and unexposed side, fixing the L-shaped and U-shaped profiles to the sandwich panel</p> <p>Ø8.0 x 60 mm (with 8 mm plugs): around the perimeter of the partition (except free edge), on exposed and unexposed side, connecting the L-shaped profile to the supporting construction.</p> <p>Ø4.8 x 90 mm: on the exposed side fixing the sandwich panels to each other along the vertical sides</p> |

2.3 METHOD OF ASSEMBLY

The test specimen was built in the following order:

- Fixing of L-shaped profiles to the supporting construction on one side;
- mounting the panels to the L-shaped profiles;
- mounting the L-shaped profiles on the other side;
- applying screws to connect the panels to each other.

3. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THE CLASSIFICATION

3.1 TEST REPORTS

Table 3.1: Details test report

| Name of laboratory | Name of sponsor | Report ref. no | Test standard and Date |
|-----------------------------|------------------------|-----------------------------|-------------------------------|
| <i>Efectis Nederland BV</i> | <i>SAB-profiel bv</i> | 2021-Efectis-R000169[Rev.1] | <i>EN 1364-1:2015</i> |

3.2 RESULTS

Table 3.2: Summary of test results

| Criterion | Time [min] | Time of reaching a criterion measured from the start of the test in accordance with EN 1364-1:2015 |
|--|------------|--|
| Integrity (E) | | |
| -Cotton pad | 48 | Not applied |
| -Gap gauge Ø 6 mm | 48 | Not applied |
| -Gap gauge Ø 25 mm | 48 | Not applied |
| -Sustained flaming > 10 seconds | 47 | Failure |
| Insulation (I) | | |
| -Average temperature | 48 | No Failure |
| -Maximum temperature | 16 | Failure tc 12 |
| Heat Radiation (W) | | No failure, max. 2.4 kW/m ² at 48 min. |
| The maximum deflection was 106 mm at 48 minutes. | | |
| The heating was terminated after 48 minutes after consulting the client. | | |

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with Clause 7 of EN 13501-2:2016.

4.2 CLASSIFICATION

The element, "SAB WB 100.1000 EW30" is classified according to combinations of performance parameters and classes as described in Clause 6.7 of EN 13501-2:2016.

E 45, EI 15 and EW 30

4.3 FIELD OF APPLICATION

4.4 GENERAL

The results of the fire test are directly applicable to similar constructions where one or more of the changes listed below are made and the construction continues to comply with the appropriate design code for its stiffness and stability, except with respect to the construction types covered in annex A and annex B of EN 1364-1 where specific direct field of application rules are given.

- a) decrease in height;
- b) increase in the thickness of the wall;
- c) increase in the thickness of component materials;

- d) decrease in linear dimensions of boards or panels but not thickness;
- e) decrease in stud spacing;
- f) decrease in distance of fixing centres;
- g) increase in the number of vertical joints, of the type tested;
- h) vertical joints, of the type tested.

4.5 EXTENSION OF WIDTH

For test specimens tested with a supporting construction, the width of an identical construction may be increased if the specimen was tested at a minimum of nominally 2,8 m wide with one vertical edge without restraint.

In case of EW classification, an increase in width of an identical construction is only allowed when the average unexposed surface temperature of any discrete area of the test specimen remains below 300 °C or the measured radiation remains below 6 kW/m². In any other case, no increase in width is allowed.

4.6 EXTENSION OF HEIGHT

The height of the construction may be increased by 1.0 m under the following conditions:

- a) minimum tested height is 3 m when tested without a supporting construction or 2.8 m when tested with a supporting construction;
- b) the maximum deflection of the test specimen was not in excess of 100 mm;
- c) the expansion allowances are increased pro-rata.

In case of EW classification, an increase in height of an identical construction is only allowed when the average unexposed surface temperature of any discrete area of the test specimen remains below 300 °C or the measured radiation remains below 6 kW/m². In any other case, no increase in height is allowed.

4.7 SUPPORTING CONSTRUCTIONS

The following rules for the field of application apply.

4.7.1 Standard supporting constructions

For specimens tested with any standard supporting construction as defined in EN 1363-1, the result is applicable to any other supporting construction of the same type (flexible or rigid) that has the same or a greater classified fire resistance (thicker, denser, more layers of boards, as appropriate) than the one used in the test and the same horizontal and/or vertical orientation, i.e. only vertical if the specimen was tested with the standard supporting construction fixed along the vertical edge.

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

SIGNED



A.J. Waber M.Sc.
Project leader fire resistance

APPROVED



G.M. Klijn B.Sc.
Project leader fire resistance

6. DRAWINGS




Figure 1: Overview




Figure 2: Detail AA




Figure 3: Detail BB




Figure 4: Detail CC




Figure 5: Detail DD